

Delivering low cost, reliable & clean energy

Consumer Advisory Panel | Roundtable #2 Topic: Constructing Marinus Link

3 May 2022

Stephen Clark Project Director

These records and accompanying documentation prepared by representatives or consultants working on Marinus Link are intended for public release.

Acknowledgement of Country



AGENDA

2:00pm

Meeting Start – Heath Dillon

- Acknowledgement of Country
- Introduction
- Housekeeping
- 2:05pm Today's purpose Heath Dillon
- 2:10pm Constructing Marinus Link Stephen Clark
- 2:50pm Q&A- Mandi Davidson
- 3:00pm Meeting close Mandi Davidson

Next roundtable session The Marinus Link business case with Ben White Fri 13 May | 2:30pm – 3:30pm Today's purpose Heath Dillon, Executive Manager Customer and Revenue



Constructing Marinus Link Stephen Clark, Project Director



What is Marinus Link?

- 1500 MW of increased transmission capacity between Tasmania and Victoria
- Increased fibre optic cable capacity across Bass Strait
- ~250km undersea, ~90km on land cable
- +/- 320kV (2 x 750 MW monopoles)
- No DC overhead lines planned
- Using modular multi level voltage sourced converter technology
- Significant upgrades to the AC Tasmania transmission system
- Tasmanian AC switching station at Heybridge
- Victorian AC switching station at Hazelwood (or alternate site at Driffield under consideration)
- For RIT-T and ISP purposes, Marinus Link and North West Tasmanian Transmission Developments (NWTD) are collectively referred to as the Marinus Link interconnector



What is North West Transmission Developments?

- Upgraded and new AC transmission lines in North West Tasmania including:
 - double circuit 220 kV 'rectangle' connecting Sheffield and Burnie substations with new switching stations in Hampshire Hills and Staverton;
 - New transmission between Sheffield and Palmerston (near Cressy) and the removal of the existing line.
- The proposed developments are designed to:
 - unlock the energy potential identified by AEMO in North West and Central Tasmanian REZs;
 - facilitate connection of additional energy generation and storage in Tasmania; and
 - ✓ support energy flows to/from Marinus Link.



*North West Transmission Developments indicative routes



HVDC Technology and Converter/Switching Stations





Configuration of link for 1500MW

- Configuration: either 2 x 750MW monopoles or 1 x 1500MW bi-pole.
- Both configurations limit the largest contingency size to 750 MW
- Features of 2 x monopole configuration:
 - proven technology
 - provides more security
 - smaller environmental impact; only two cable trenches in Bass Strait and less EMFs
 - commissioning can be staged
 - Ionger cable manufacturing time



DOG





VSC HVDC Converters

- Fully controllable no commutation faults, no filters, no dead zone, no transient overvoltage issues, no minimum system strength requirements. P/Q and V/F control modes
- Bi-directional current fast reversal, can continuously provide frequency control services
- Stabilises the power system during electrical faults fast recovery after faults
- Almost zero 'electrical pollution' in the form of harmonics
- Uni-directional Voltage multi-terminal, less stress on cable (can use XLPE cable)
- Converter power losses similar to LCC converters
- Can act as a firewall to stability and cascading failures



Inside Nordlink – 1400 MW bi-pole 500km long cable



NordBalt 700MW Symmetrical Monopole

400 km Marine & 40 km land XLPE AI cable 300kV









CONFIDENTIAL



Auxiliaries: control building, valve cooling, Medium voltage switchgear, 220V/110V, batteries, SCADA, HVAC, ...





Valve Cooling





Primary circuit (inside) Demineralised water

Heat evacuation to environment (outdoor cooler bank)



Secondary circuit (outside) Glycol water

Heat exchanger

Cables

111



Cable options for HVDC

MIND Cable



XLPE Cable



XLPE is preferred due to lower cost and faster installation.

Cable technology risk



● MI ● Under construction MI ● XLPE ● Under construction XLPE

- Bag alm

Cable manufacturing process



On Land Construction





Construction Corridor

INDICATIVE CONSTRUCTION CORRIDOR LAYOUT



Installed using open trenching The standard construction corridor will be up to 36 meters wide



Horizontal Directional Drilling (HDD)

INDICATIVE CONSTRUCTION





Jointing

Jointing of the Cables



Shore Construction Method

Cross section of landing site

INDICATIVE CONSTRUCTION





Subsea Construction





Preparing the Cable Route and Laying and Burying of the Cables





The majority of the subsea cable route has a soft, sandy seafloor, allowing for a water jetting trencher to be used to bury the cables safely and with a low impact to the surrounding environment

Subsea Construction

Where the seabed is hard, the cables will be laid and then protected by using subsea mattresses.



Construction Impacts

ON LAND

Most impacts to native plants, animals and cultural heritage values will be minimised either through minor changes to the route or by using HDD to install the cable in specific locations.

SUBSEA

The proposed route has been chosen to avoid seabed habitats of significance.

The cable installation process causes disturbance of the seabed, which is generally sparsely populated with marine plants and animals along the proposed route.

IMPACT FROM ELECTROMAGNETIC FIELDS (EMF)

EMF occur naturally in the environment because of the earth's magnetic field. EMF are also created by everyday electrical equipment like mobile phones and power lines, as well as the undersea cables of Marinus Link.

Research shows that EMF produced by subsea cables designed like Marinus Link does not create a barrier to sensitive species and they will be able to easily navigate past the cable.

Procurement Strategy Stephen Clark, Project Director



Packaging Strategy



*In Victoria the switching station is an option as it is subject to contestability rules

- 305 a

Cable Demand

Global Total Demand vs. Global Supply



Globally 19300km HVDC cable is required to 2025 Global HVDC subsea cable demand by contract status



DOG

Uncontracte d

Contracted

Procurement Timetable

Activity	Revised Strategy (Mar 2022) Calendar Year*
Prequalification process commences	Q3 2021 (complete)
Prequalification process concludes	Q4 2021 (complete)
Preparation of Request for Tender (RFT) documents	Q4 2021 to Q2 2022 (in progress)
Submarine cable RFT issued	Q3 2022
Converter RFT issued	Q3 2022
Site establishment RFTs (for converter station sites) issued	N/A
Board and any Government approvals of proposed successful cable and converter tenderers	Q2 2024
All cable and converter contracts ready for award	Q3 2024
Final Investment Decision – Stage 1	Q4 2024
Contract award	Q4 2024

* Revised dates are aligned to latest approved project schedule

Next Steps

Local Content

- Established a supply chain portal with the Industry Capability Network (ICN) where suppliers including local businesses can register their interest in the project.
- Engaging with social enterprises to identify socially orientated firms that could supply aspects of the project's requirements.
- · Tenders will need to complete an Australian Participation Plan
- More information on the procurement strategy including risk allocation will be discussed at the deliberative workshop session being held on 30 and 31 May 2022 in Melbourne







Delivering low cost, reliable & clean energy

Find out more:

marinuslink.com.au

Email the team: <u>team@marinuslink.com.au</u>



Thank you

